

7 - TYPICAL PRESSURE DISTRIBUTION SYSTEM

Cleanout on end
of each lateral

Maximum Orifice
Spacing 60"

MINIMUM
48"

Fittings to allow rotation
of laterals after testing

24" to 36"

One to two inch nominal diameter,
Class 160, Schedule 40 or Schedule
80 rigid plastic pipe.

Force main from dosing tank,
Minimum one inch diameter,
Class 160 or better

1/2 orifice spacing
to first orifice

NOTE:
Orifices up for testing and
rotated down for operation

